

XP CLIMATE CONTROL LLC. CERTIFICATE OF CONFORMANCE

National Electric Code

Explosion Proof HVAC Equipment

The certificate certifies that to the best of our knowledge the equipment manufactured

Model Number: EP-MS18HP-2-2-X-(IE)-216-1Z

conforms to the requirements the

United States of America National Electrical Code

for the following locations:

Interior and Exterior Section: Class 2 Division 2 Groups E, F, and G.

The equipment shall be installed and operated only in the hazardous locations identified in this certificate and in accordance with applicable code requirements.

Conformance I.D. CC-COC-113-Standard, NEC Article 500.
IEC Zone II Groups IIA and IIB-T3

Certified by XP Climate Control LLC.
